

Attestation

We confirm in line with the result of Test Report no. 19-410-02274-PB
that the CIPP hose liner system

“RS MaxLiner”

with the system components

**MaxLiner SuperFlex, MaxPox Fill A and MaxPox Fill B90
MaxLiner Flex S, MaxPox 15M and MaxPox 70
MaxLiner Flex S, MaxPox 5 Eco and MaxPox 112 Eco**

manufactured by

RS Technik AG


Bergkamen subsidiary
Zum Schacht III 9
59192 Bergkamen
Germany

has, for all tested material combinations and for the test parameters
0.5 bar pressure and a 24 h test duration,
created a watertight, infiltration-proof connection with the
materials of the rehabilitated pipes made of
PE-HD, PP-HT, PVC-U KG, PP-KG2000 and GG-SML.

SIEBERT + KNIPSCHILD GMBH

Ingenieurbüro für Kunststofftechnik
Bergstücken 25
22113 Oststeinbek

Germany



Dipl.-Ing. Andreas Haacker
Oststeinbek, May 7, 2019